



Serving Learners, Families, and the Community

CECIL COUNTY PUBLIC SCHOOLS PURCHASING OFFICE

GEORGE WASHINGTON CARVER EDUCATION LEADERSHIP CENTER
201 BOOTH STREET • ELKTON, MD 21921

phone: 410.996.5429 • fax: 410.996.1081 • www.ccps.org

Jeffrey A. Lawson, Ed.D.
Superintendent of Schools

William H. Malesh
President, Board of Education

June 9, 2021

CCPS Bid #21-10 – Bohemia Manor High School – Packaged Heat Pump Replacement Project

ADDENDUM #1

This addendum is to answer questions asked via email and/or at the non- mandatory walk-through meeting held on June 2, 2021. Proposers and related parties will be responsible to have read and understand all documents, the scope of work, addenda and all related solicitation documents issued. These documents will become attached to and part of the solicitation and award of bid contract.

CONTRACTOR QUESTIONS

QUESTION 1: The scope calls out to reuse the existing 208V for one of the units. Is this electrical feed the correct size to feed the new (3) Ton unit.

ANSWER 1: Remove feed and breaker from 1.5 ton unit and replace with feed and breaker of appropriate rating from electric panel to the new Bard Unit.

QUESTION 2: If a new feed is required what is the approximate length of the feed from the electrical panel to the new unit?

ANSWER 2: Electric panel is approximately 10' from the heat pump location

QUESTION 3: The remaining (1.5) ton unit that will remain in place will be disconnected from the power source per the work specification. Is it acceptable to disconnect, remove and leave the wire feed near panel taped and marked? Or is it required to demo the entire 208V feed?

ANSWER 3: It is not required to demo the entire feed.

Authorized Signature/Date: _____

Printed Name/Title: _____

Contractor Name: _____

Address: _____

***Note: Bidder must sign and submit Addenda with the proposal submission. The same person signing the Addenda acknowledgement(s) must sign the Bid Form.**